

ADDENDUM NO. 1

FOR

MANVILLE PARK AND ALBION PARK BASKETBALL COURT REPAVING RFP #2024-02

July 27, 2023

NOTICE TO PROSPECTIVE BIDDERS

Prospective bidders are hereby informed of the following corrections, additions, deletions, and/or modifications to the bidding documents for the **Manville Park and Albion Park Basketball Court Repaving RFP #2024-02**. This Addendum No. 1 forms a part of the bidding documents and all changes shall be incorporated into the Bid Proposals. **Bidders must acknowledge receipt of the addendum on the line provided on the revised Bid Form included as Exhibit A in this RFP. Bidders who fail to acknowledge receipt of this Addendum No. 1 on the Bid Form will not be considered for award.** Please note that the bid due date has not changed.

Part 1 – Responses to Questions

The following questions were received from prospective bidders by 5:00pm on July 26, 2023. The questions are italicized and the answers follow.

GENERAL QUESTIONS

1. *Where is new gravel required? It is called out at Manville but not Albion.*

The Manville Court is being widened by one foot on the northwestern edge of the existing pavement to provide a 3' wide paved space outside of the court.

2. *Can an alternate, such as Novarylic, be used in place of plexipave.*

Novacrylic is an acceptable alternate.

3. *What do we do with concrete around the basketball hoops?*

The concrete is at finish grade. Leave the concrete and match the new asphalt to it.

4. *What do we do with the benches and tables at Manville?*

Remove and dispose the benches, table, and their footings.

5. *Should the court match up with the asphalt walkway at Albion Park?*

Yes

MANVILLE PARK AND ALBION PARK BASKETBALL COURT REPAVING
PRE BID MEETING - SIGN IN SHEET

July 18, 2023
10:00 AM

PLEASE PRINT LEGIBLY

Name	Company	Phone Number	Email
JON TRAKAS	NARR. IMP. Co.	(401) 331-7420	jtrakasonicori.com
MIKE HEDLEY	BB INC.	401-781-7750	beausoleilbros.com