

**Addendum #1
for
RFP #2024-03
Reconstruction of Bocce Court**

NOTICE TO PROSPECTIVE BIDDERS Prospective bidders are hereby informed of the following clarifications to the bidding documents for the Reconstruction of the Bocce Court. This Addendum No. 1 forms a part of the bidding documents and all changes shall be incorporated into the Bid Proposals. Please note that the bid due date has not changed. The following questions were received in writing from prospective bidders by 4:30 pm on October 13, 2023. The questions are italicized and the answers follow.

QUESTIONS & ANSWERS:

1. Town lengths of pipe covering the full dimension of the bocce court.

Should be two lengths of pipe covering the full dimension of the bocce court.

2. Please clarify "4" drain tiles. Are you referring to 4" perforated pipe?

Yes, 4" perforated pipe.

3. Installing a drainage system (if needed), should that cost be carried in the base bid, will it be addressed as a CO or is it an Add Alt?

The Town wants the drainage system replaced and the cost should be carried in the base bid.

4. Can the site be seen?

Yes, the site can be seen at any time. The location of the bocce court is at the Lincoln Senior Center, 150 Jenckes Hill Road, Lincoln, RI.